








CHENNAI METRO RAIL LIMITED

CHENNAI – 600107

CONTRACT NO: BW-UG-02-Stations

“Design and construction of balance works of underground stations at Government Estate, LIC and Thousand Lights”.

ATTENDANCE SHEET OF THE PRE-BID MEETING FOR TENDERERS

Sl.No	Name of Contractor	Contractor's Address	E-mail Id & Contact Number	Name & Signature of Contractor's Representative
1.	LFT	manapakkam Chennai	amisha@lntec.com ASHUTOSH MISHEA	
2.	Hce Ltd.	HINCON HOUSE 1B5 MARGA, METTUR, 83	Sadaramam.murugan HCEINDIA.COM	
3.	Coastal Projects	Hindurabad,	tiyanambalaji@coastalproject.com	
4.	URC Construction (P) Ltd.	Bangalore	urctender@gmail.com	N. Saha 
5.	URC ,, (KINTSMEVRAH CONSULTANTS)	DELHI	urcpl@kscpl.net	
6.	AFCONS INFRASTRUCTURE LTD	MUMBAI	tasoon@aofcons.com	Z. Kulkarni 
7.	VUCTRA Ltd.	Chennai	Venrusuban@vulltra.com	

CHENNAI METRO RAIL LIMITED

CHENNAI – 600107

CONTRACT NO: BW-UG-02-Stations

Design and construction of balance works of underground stations at Government Estate, LIC and Thousand Lights”.

Details of CMRL Representatives attending the Pre-bid conference held on 13.01.2016 at 15.00 Hrs at 1st Floor Conference Hall, CMRL, Chennai 600 107.

ATTENDANCE SHEET

Sl.No	Name	Designation
1.	ARVIND K RAI	GM/UG, CMRL
2.	YASIN. M.	AGM/UG, CMRL.
3.	S. Subramaniam / GC	Sr. Quantity Surveyor GC.
4.	REKHA PRAKASH / CMRL	Jhm (DESIGN)
5	R. vignesh	Amuz
6	R. RAJASEKHARAM	mgt/design

MINUTES OF MEETING

CONTRACT BW-UG-O2-STATIONS : Design and Construction of Balance Works of Underground Stations at Government Estate , LIC and Thousand Lights

Pre Bid Meeting Held on 13th January 2016 at CMRL

S.No.	Queries raised by Tenderers	Reply by CMRL
1.	Separate KDs should be there for each station as well as for entry structures.	KDs will be revised for each station and will be intimated in Addendum a) Work above roof slab, Entry structures & Ancillary Building shall be given as a separate KD b) Concourse slab work shall be given as a separate KD c) Work below concourse slab, Platforms and other system rooms shall be given as a separate KD
2.	Separate KD for entry structures where they can't be taken up simultaneously.	Separate KD shall be made for Entry structures, where Traffic diversion is necessary to take up the other Entry Structures.
3	Design Checking responsibility of the contractor	a) Clarified that for Works completed, the design responsibility lies with CMRL b) For Works that are not completed but designs / drawings available, they are to be checked and executed by Contractor. The Contractor is responsible for the correctness of the Design c) For Works that are not completed and designs / drawings not available, they are to be designed, checked by LDC and got approved by CMRL/GC before execution.
4.	Whether JV permitted ?	JV is permitted to be formed for Bidding. The Typo error in the documents will be corrected in the addendum
5.	Requested to see Designs and Drawings related to D'wall of Stations	D'wall Designs & Drawings are available with CMRL. If required, interested Bidders can Approach CMRL with a letter to collect one Typical Designs and Drawings related to D'wall of Stations
6.	Specific Experience criteria in Initial Filter, Bidders wanted to know if the value of INR 300cr mentioned for Minimum value of work is correct	The Criteria Shall be suitably incorporated in the Addendum

7.	Muck Disposal Site	It was clarified that Muck disposal site has already been identified by CMRL and shall be intimated after award of contract.
8.	Payment during the period of Extension of time	CMRL will spell out the policy by which, the amount that can be paid / or not paid during extension of time of the contract shall be specified. Refer Addendum
9.	Interim Payment to be made only if value of work done is more than 2% of contract Value. Bidders want it to be changed to 1% of Contract value.	Agreed.
10.	Contractor's Tools and Plants – Whether Hired T&P acceptable ?	a) Yes. b) Provided documentary evidence of Ownership of Equipment and Letter of intent of equipment owner showing his willingness to let-out the equipment to the Bidder are submitted to CMRL.
11	Availability of Land for Entry Structures	Clarified that required land is already in possession of CMRL.
12	Whether Experience in Building Basement Construction considered as Experience for UG metro station?	NOT ACCEPTABLE.
13	Interfacing with Other contractors and sharing of resources.	It was clarified that, the sharing of power, ventilation etc shall be based on the mutually agreed rate between the interfacing contractors.
14	Time limit for submission of additional Queries by E- and issue of addendum	It was agreed that Last date for submission of additional Queries by E-mail shall be up to 12.00 hrs of 23.01.2016 and addendum shall be issued by 31.01.2016

CGM(UG-C)