

CHENNAI METRO RAIL LIMITED

ADDENDUM No.1

Tender Reference No: CMRL/ Parking Shed Area /SPV/03/001/2016.**Dated:** 24.08.2016

Tender for *Design, Manufacture, Supply, Erection, Testing and Commissioning of solar PV panels including warranty, Operation and comprehensive maintenance for a period of 25 years on RESCO model in CMRL Admin Car parking Shed.*

S.No	Page. No	Tender Clause No	Description	Addendum/Amendments to the Bid Document
1	11	1.1	Grid Connectivity	"The generated solar power will be utilized for captive application of CMRL and the surplus power will be fed to the CMRL grid. The scheme aims to reduce the fossil fuel based electricity load on main grid and make building self-sustainable from the point of electricity, to the extent possible." Shall be read as " <i>The generated solar power will be utilized for captive application of CMRL only</i> ".
2	11	2.2	Correction	Shall be read as " <i>Bidders will be required to submit a fixed tariff rate for 25 years, Bidders are required to quote tariff rate with three decimal places. (E.g. Rs. X.XXX).</i>
3	12	2.3	Correction	Area of Shed is 1000 Sq.m - Project Capacity 100 KW. <i>.Bid Details as per clause 2.0 shall be read accordingly.</i>
4	14	3.4.3	Correction	The sentence " <i>the bidder should at least have completed one financial year of commercial operation</i> " is deleted.
5	20	3.14	Clarification	<i>No Change in EMD clause, EMD is mandatory as per the CMRL Tender procedure.</i>
6	31	6.2.2.b	Correction	Shall be read as " <i>Bidders will be required to submit a fixed tariff rate for 25 years, Bidders are required to quote tariff rate with three decimal places. (E.g. Rs. X.XXX)</i> "

CHENNAI METRO RAIL LIMITED

7	33	8.3	Addition	<i>“ The generated power should be synchronized with the LT side (415 V) of 33 KV substation”</i> is added
8	34	8.5	Correction	“The Modules should be manufactured in India only.” Shall be read as <i>“ The modules may be manufactured anywhere”</i>
9	40	17h	Clarification	Provision of Poly carbonate sheet between PV panels is in the scope of bidder
10	66	ii & iii	Deletion & correction	The Points are deleted and shall be read as <i>“The Annual turnover of Rupees 1.0 crore in any one of the last 3 financial years preceding the Bid Deadline</i>
11	81	Annexure –B	Addition	RBL Bank is added to the List of Banks

This Addendum forms the part of the Tender Document (Technical Bid) and is required to be signed and sealed by the bidder while submitting bids to CMRL.

Date:

SE / ELECTRICAL