

Chennai Metro Rail Limited			
NIT No. Tender No. CMRL/CON/SAL-FOB/RT-01/2017			
Pre-bid Meeting held on 02.03.2017- Replies to Queries Addendum -1			
NIT No. Tender No. CMRL/CON/SAL-FOB/2017 is to be Read as NIT No. Tender No. CMRL/CON/SAL-FOB/RT-01/2017			
S.No	Bidders Query	CMRL Reply	Amendment to Relevant Clause in Bid Document
1	Deck sheet mentioned in the Drawings, but missing in BOQ item: Quantity to be added in BOQ and thickness to be corrected the drawings since the deck sheet available is only 0.8mm to 1.2mm thick	<p>Deck Sheet Quantity is already included in the Bill of Quantities as Item No - 15. The thickness for the corrugated sheet should be considered as 1.00mm instead of 15.0mm.</p> <p>Item is changed from "Red Mud Plastic (RMP) corrugated sheet" to "Corrugated G.S. sheet roofing (1.00 mm thick with zinc coating not less than 275 gm/m²)".</p> <p>Thickness of the Deck Sheet is corrected in the Tender Drawings.</p>	<p>Specification is changed from "Supplying and fixing Red Mud Plastic (RMP) corrugated sheet including fixing with adjustable ridge seated U or J bolts nuts and bitumen washers etc complete. (ISI STD)"</p> <p>is to be Read as</p> <p>"Providing corrugated G.S. sheet roofing including vertical / curved surface fixed with polymer coated J or L hooks, bolts and nuts 8 mm diameter with bitumen and G.I. limpet washers or with G.I. limpet washers filled with white lead, including a coat of approved steel primer and two coats of approved paint on overlapping of sheets complete (up to any pitch in horizontal/ vertical or curved surfaces), excluding the cost of purlins, rafters and trusses and including cutting to size and shape wherever required.(1.00 mm thick with zinc coating not less than 275 gm/m²)".</p> <p>Also refer addendum-1</p>

2	Utility shifting / safe guarding items are missing in BOQ: Quantities to be added in BOQ and GPRS survey to be given to the contractors	GPRS Survey Drawings are already included in Tender Drawings, refer DWG NO - IS - 1423- HIG -UTG-001.	Refer Tender Document (Page No 343).
3	Space for fabrication, stocking of materials: We request 40M X 60M land from CMRL nearest work site for assembling and painting works.	Tender Conditions prevails.	Refer Technical Specification for Structural Steel Works: Clause No 5.7 (Page No 227) Tender Conditions prevails.
4	When to pay performance security	Tender Conditions prevails.	Refer Tender Document, F. Award of Contract: at Clause No 30.1 (Page No. 26) Tender Conditions prevails.
5	Barricade boards: We request CMRL to provide the same and we pay the charges for same	Tender Conditions prevails.	Refer Bill of Quantities Item no 31 and 32. Tender Conditions prevails.
6	15-day one-way block at time of erection: Each girder is 20M width and no intermediate support, so we request for this provision	Tender Conditions prevails.	Refer Tender Document, Other Requirements / Specifications: Clause No 1.2.10 Traffic Diversion. Page No 267 Tender Conditions prevails.
7	Approvals of Public authority and other statutory requirements: Contractors will coordinate with departments with CMRL suggestions	Tender Conditions prevails.	Refer Tender Document, Section - X Technical Specifications: Clause No 2.2.1 Benchmarks and Setting out of Works. (Page No 151) Tender Conditions prevails.
8	Sections mentioned in drawings with 10mm thickness is not available from approved manufacturers: We request to revise the drawings instead of 10mm, we may recommend 8 or 12mm	Tender Conditions prevails. At design stage, various manufactures were confirmed that the material will made available subject to the order confirmation.	Items should be executed as per Tender Drawings Tender Conditions prevails.

<p>9</p>	<p>Material advance: Since the project 80% cost to be invested in 1st 2months to pay advances for lifts & escalators, purchase of structural steel for fabrication and till erection, we request advances against L.C we made to lift vendor and for structural steel once arrived at site.</p>	<p>Tender Conditions prevails.</p>	<p>Refer Tender Document, Section V: Conditions of Contract: at Clause- 46.1 (Page No 78) Tender Conditions prevails.</p>
<p>10</p>	<p>Average Annual Turnover: We attach audit report, payments ledger from CMRL and Bank statement.</p>	<p>Tender Conditions prevails.</p>	<p>Refer Tender Document, A. General: at Clause - 3.4 a (ii) (Page No 16) Tender Conditions prevails.</p>
<p>11</p>	<p>Checklist number 5, similar works and number 6 minimum quantities: Type of documents contractor need to show as proof of these items</p>	<p>For Checklist No.5 : Work done Certificates or Completion Certificates from the Centre Government of India / State Government Department / Government undertaking in India is to be submitted as the proof.</p> <p>For Checklist No.6 : updated refer addendum-1</p>	<p>Check List: Clause - 6 (Page No 10) Minimum Quantities of work at least any one year during the last five years is changed from (i) RCC (M25) - 90 cum (ii) Steel Reinforcement - 130 MT (iii) AC Sheet - 980 Sqm (iv) Weld mesh for - 275 Sqm</p> <p>to be read as</p> <p>(i) RCC (M25) - 110 cum (ii) Structural Steel - 130 MT (iii) G I Sheet - 725 Sqm (iv) A C Pannel - 385 Sqm</p>

<p>12</p>	<p>Checklist items item 2, CPWD registration. Items 5 and 10 ie. More than 5 years: We wish to introduce our electro mechanical firm as a Joint Venture for this project since lead bidder has finished the similar works, quantities and having enough turnover, requesting for an approval.</p>	<p>Tender Conditions prevails.</p>	<p>Refer Tender Document, Check List: at Clause - 2 (Page No 9). A. General: at Clause - 3.4 a (ii) (Page No 16) Tender Conditions prevails.</p>
-----------	--	------------------------------------	---